

NSG 4070B APPLICATION FOR NISSAN 28400NDS91

Test parameter

Standard:	Nissan 28400NDS91
Frequency range:	1 MHz to 400 MHz
Level 1:	20 to 60 mA
Level 2:	33 to 100 mA
Level 3:	66 to 200 mA
Modulation:	e.g. CW, 1 kHz AM 80% (Peak conservation)
Test method:	Substitution method with optional monitoring probe
Monitoring probe:	only for information (substitu- tions method)


Equipment

Signal generation:	NSG 4070B-0
Modulator:	included in NSG 4070B-0
Power meter:	3x included in NSG 4070B-0
Power amplifier:	CBA 400M-110
Directional coupler:	DCP 0100A
Current injection probe:	CIP 9136A
Monitoring probe:	MD 4070
Calibration jig:	PCJ 9201B
Termination:	50 Ω 10 W
Attenuation:	20 dB 10 W
Software:	incl. in NSG 4070 or optional C5I or WIN 6000




WARNING: The power meter inputs are very sensitive. It is the user's responsibility to ensure that the selected test levels does not damage the equipment. Any hardware/setup changes should be calculated before starting the test.

Calibration set-up for monitoring probe




Remarks:

The monitoring probe MD 4070 needs to be calibrated in the way of its use (active, passive or with switching at a specific frequency from active to passive).



Test level — for Nissan 28400NDS91 Level 1
 Test level — for Nissan 28400NDS91 Level 2
 Test level — for Nissan 28400NDS91 Level 3


Calibration set-up for all levels



Attenuator: 20 dB, 10 W
 Termination: 50 Ω 10 W

Remarks:
 Power meter channel 1 needs to be protected with a 20 dB attenuator.

Test set-up with monitoring probe



Use of MD 4070 in the passive mode.
 Caution:
 The use of the MD 4070 in the active mode during tests with stress levels above 20 mA could damage power meter channel 1 of NSG 4070.